



INDOOR POOL

SELF ASSESSMENT CHECKLIST



Window restrictions for indoor pools



Any openings (within 1800mm height) shall be permanently restricted to a maximum of 100mm.

☐☐

Any windows located within 1200 mm of the pool area that can be opened and have gaps larger than 100 mm must be fitted with a secure barrier fixed to the building.

☐☐

Any openings (within the 1200mm height) in the window shall not be able to be opened greater than 100mm.

☐☐

Doors that have access to pools



Gate latch release height must be at least 1400mm above any lower foothold

☐☐

Doors open away from the pool area and are self-latching

☐☐

There are no pet doors or openings greater than 100mm

☐☐

Wall restrictions for indoor pools



There are no wall openings greater than 100mm

☐☐

Around the pool



There is an appropriate warning sign, including details of resuscitation (CPR) techniques, in the immediate vicinity of the pool area which can be easily read from a distance of 3 metres.

☐☐

An owner may install the pool only after a safety barrier is installed and checked by a licensed building surveyor.

If you have answered 'No' to any of the questions above, please contact your local council for further information.
drowningprevention.org.au/swimmingpoolready



ROYAL LIFE SAVING
TASMANIA